

BRANZ Type Test Summary

This is to certify that the specimen described below has been tested by BRANZ Ltd on behalf of

Armacell Australia Pty Ltd
13-17 Nathan Road
Dandenong South
VIC 3175
Australia

Test standard: ISO 5660 Parts 1 and 2

Specimen name: Armaflex FRV

Specimen description: Dark grey thermal insulation based on a modified NBR rubber system containing inorganic filler systems and plasticizers with fire retardant properties.

Orientation: From the direction tested.

A full description of the test specimen and the test results are given in BRANZ Test Report:

Fire Test FH 5504-TT – Test dates 13th and 18th of March 2014

Regulatory authorities are advised to examine test reports before approving any product.

The test results were the basis for the following:

Building Code Document	Group Number Classification
NZBC Verification Method C/VM2 Appendix A	1

Issue Date:
1 April 2014

Expiry Date:
1 April 2019



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.